

# Emission Test Certificate

Wednesday March 3<sup>rd</sup>, 2010

Supplier: The Laminex Group (21 Trewin Street, Wendouree Victoria 3355)

Sample Description: 7229 (33mm Spaceboard)

Date Tested: February 2010 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

## 7229 33mm Spaceboard

Total Volatile Organic Compound Emission Rate: <0.01 mg/m<sup>2</sup>/hr (7 days)

When this product is used in the typical manner in an office building the resulting airborne total volatile organic compound concentration can be expected to be less than 0.5 mg/m<sup>3</sup> as specified by Green Building Council of Australia Green Star Office Interiors IEQ-11.



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

**Project CV100204**