

Emission Test Certificate

Friday June 12th, 2009

Supplier: The Laminex Group (21 Trewin Street, Wendouree Victoria 3355)

Sample Description: 16mm Plylite Plywood (6074)

Date Tested: June 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

16mm Plylite Plywood

Total Volatile Organic Compound Emission Rate: 0.2 mg/m²/hr (7 days)

When this product is used in the typical manner in an office building the resulting airborne total volatile organic compound concentration can be expected to be less than 0.5 mg/m³ as specified by Green Building Council of Australia Green Star Office Interiors IEQ-11.



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Project CV090613