

Emission Test Certificate

Monday, October 25th, 2011

Supplier: The Laminex Group (21 Trewin Street, Wendouree Victoria 3355)

Sample Description: Laminex Structural MDF Sample 10724

Date Tested: October 2011 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

Green Building Council of Australia Green Star Office Interiors IEQ-11	Laminex Structural MDF Sample 10724
Total Volatile Organic Compound Emission Rate limit <math><0.5\text{mg}/\text{m}^2/\text{hr}</math>	Total Volatile Organic Compound Emission Rate: <math><0.238\text{ mg}/\text{m}^2/\text{hr}</math> (24 hours)



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Anne Saletti
BNanotech/BSc(Hons)
Consultant

CV110716B