

Emission Test Certificate

Tuesday July 6th, 2010

Supplier: The Laminex Group (21 Trewin Street, Wendouree Victoria 3355)

Sample Description: Laminex Compact Laminate

Date Tested: June 2010 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

Laminex Compact Laminate

Total Volatile Organic Compound Emission Rate: <math><0.003 \text{ mg/m}^2/\text{hr}</math> (7 days)

When this product is used in the typical manner in an office building the resulting airborne total volatile organic compound concentration can be expected to be less than 0.5 mg/m^3 as specified by Green Building Council of Australia Green Star Office Interiors IEQ-11.



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Project CV100606