

# Emission Test Certificate

Thursday July 31<sup>st</sup>, 2008

Supplier: The Laminex Group

21 Trewin St

Wendouree Victoria 3355

Sample Description: Classic Gloss Vinyl Door (MDF substrate with vinyl wrap on the front surface and a white low-pressure laminate on the back)

Date Tested: July 2008

Test Method: ASTM D5116 "Standard Guide for Small -Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

## Classic Gloss Vinyl Door

Total Volatile Organic Compound Emission Rate: 0.05 mg/m<sup>2</sup>/hr (7 days)

When this product is used in the typical manner in an office building the resulting airborne total volatile organic compound concentration can be expected to be less than 0.5 mg/m<sup>3</sup> as specified by Green Building Council of Australia Green Star Office Interiors IEQ-11.



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

Project CV080722